

Estimating the technical potential for residential Demand Response in New Zealand

OERC Symposium 2018

23.11.2018

AGENDA

01

The Challenge

Demand variability and congestion periods

02

Demand Side Management

Demand Response in contrast to Energy Efficiency

03

Methods

Scenario-based analysis and economic estimation

04

Results

Maximum demand and energy potential of DR. Impact of DR on national electricity generation and economic evaluation


05

Limitations

Limitations and opportunities to enhance future work


Demand volatility

Daily average half-hour electricity generation profile in summer and winter




Congestion periods

Duration of congestion period demand events for autumn and




Two Approaches

DEMAND SIDE MANAGEMENT



DEMAND RESPONSE

Change of instantaneous demand, timing of electricity consumption, response to electricity price changes or to incentive payments



ENERGY EFFICIENCY

Reduces electricity demand in general

Does not take variable conditions in electricity generation into account

Demand profiles



Heat pumps

GREEN Grid monitored
Scaled to 638GWh p.a

Hot water heaters

GREEN Grid monitored
Scaled to 3,313GWh p.a


Refrigerators

Flat profile
Scaled to 2,074 GWh p.a

➤ **50% of total residential household electricity**

➤ **Electricity demand can in principle be shifted**



Analysis



04: RESULTS

Demand and Energy


Daily average total energy consumption profile for HP, HW, REF*1



Demand Morning Peak

Summer: Max. 860 MW


Winter: Max. 1,600 MW



Energy Morning Peak

Summer: 3,150 MWh per day


Winter: 5,120 MWh per day*2



Demand Evening Peak

Summer: Max. 760 MW

Winter: Max. 1,200 MW



Energy Evening Peak


Summer: 3,120 MWh per day

Winter: 4,920 MWh per day

04: RESULTS


Load shifting

Estimated total load shifting profile for HP, HW, and REF (scenario 2)



- Individual appliance demand as well as aggregated group demand
- Load reduction to zero at peak demand
- Load of peak times is equally spread over the prior period
- New maximum demand 1,740 MW (previously 1,600 MW)

Effects of DR



Applying load shifting reduces electricity generation per day at peak times by:

Summer:
 Morning Peak: 15 %
 Evening Peak: 14 %


HW	REF	HP
8%	5%	1%
9%	5%	1%

Winter:
 Morning Peak: 20 %
 Evening Peak: 18 %

HW	REF	HP
10%	4%	4%
12%	4%	4%

04: RESULTS

Economic analysis



Annual cost predominately determined by hot water heaters and refrigeration


Annual cost without DR: \$539M

Savings per year with DR:

Load shifting: \$72M

Reduce congestion: \$107M*¹

05: Limitations
Overview



Thank you for your attention

Carsten Dortans
Masters Candidate
Sustainable Energy Management
University of Otago

Email: carsten.dortans@postgrad.otago.ac.nz
Tel.: +64 22 392 8094



Assoc. Prof. Janet Stephenson

Dr. Ben Anderson

Prof. Michael Jack

Prof. Gerry Carrington

Dr. Sharee McNab

Assoc. Prof. David Eyers

Gwenda Crawford & Nicki Topliss

Ismaël Tall