

Confined Spaces University of Otago

Building Code	CS_id	Address	Confined Space Name	Floor	Room	Work Type	Risk Level	Comments 30/03/2016
A161	ABS-FB-A	270 Factory Road	ABS- Heating and Steam Boilers	G	Boiler N21a	Inspection, Repairs & Hot Work	High - Specific: Code RED	
A161	ABS-FB-B		Animal Breeding Station Heating & Steam Boilers	G	Boiler	Hot Work, Welding, Grinding	High - Specific: Code RED	
D205	SCO-PIT-A	260 Great King Street	Scott Pit Sump Pump	B		Inspection	High - Specific: Code RED	Steam lines DPH ADS South East Corner
D205	SCO-PIT-B		Scott Pit Sump Pump	Street		Hot Work, Welding, Grinding	High - Specific: Code RED	
D205	SCO-UF-A		Scott Basement Under floor Room B10	B	10	Inspection & Repairs	High - Generic: Code RED	Activated charcoal spread over floor - dries nasal cavity and lungs
D205	SCO-UF-B		Scott Under floor Room B10	B	10	Hot Work, Welding, Grinding	High - Specific: Code RED	
D206	HER-G29-UF-A		Hercus under floor by room G29	B		Inspection & Repairs	High - Generic: Code RED	Activated charcoal spread over floor - dries nasal cavity and lungs
D206	HER-G29-UF-B		Hercus Under floor by Room G29	B		Hot Work, Welding, Grinding	High - Specific: Code RED	
D206	HER-G38-UF-A		Hercus - Under floor Room G38	G	38	Inspection & Repairs	High - Generic: Code RED	
D206	HER-G38-UF-B		Hercus Under floor Room G38	B		Hot Work, Welding, Grinding	High - Specific: Code RED	
D206	HER-UF-A		Hercus Under floor Gas Meter Room		Gas Meter	Inspection & Repairs	High - Generic: Code RED	
D206	HER-UF-B	58 Hanover Street	Hercus Under floor Gas Meter Room	G01	Rm29 & 38	Hot Work, Welding, Grinding	High - Specific: Code RED	
D207	THS-A	266 Great King Street	Medical School Thermal Storage Tunnel		Tunnels	Inspection & Repairs	High - Generic: Code RED	

Confined Spaces University of Otago

D207	THS-B		Medical School Thermal Storage Tunnel		Tunnels	Hot Work, Welding, Grinding	High - Specific: Code RED	
D402 D403 D404-401	HA-SU-CU-A		Hayward-Surveying-Cumberland Tunnels	Linking Tunnels		Inspection & Repairs	Low - Generic: Code Blue	
D402 D403 D404-401	HA-SU-CU-B		Hayward Hall, Surveying, Cumberland Tunnels	Linking Tunnels		Hot Work, Welding, Grinding	High - Specific: Code RED	
D601	LEI-UF-A	137 Leith St	Leith Loans	B		Inspection & Repairs	VERY High - Specific: Code RED	
D601	LEI-UF-B	137 Leith St	Leith Loans - Under floor	B		Hot Work, Welding, Grinding	Very High - Specific: Code RED	
F325	PHY.ED-FLU-A		Physical Education Flume	B		Inspection & Repairs	High - Generic: Code RED	
G401	CHM1-A		Science 1 Basement Plant Room to Tunnels	B		Inspection & Repairs	High - Generic: Code RED	
G401	CHM1-B	700 Cumberland Street	Science 1 Basement & Plant Room to Tunnels	B		Hot Work, Welding, Grinding	High - Specific: Code RED	
G403	BIO-A	710 Cumberland Street	Bio Chemistry Main Tunnel to Link tunnel	B	Tunnel	Inspection & Repairs	Low - Generic: Code Blue	
G403	BIO-B	710 Cumberland Street	Bio Chemistry main Tunnel to Science 1- Link Tunnel	B		Hot Work, Welding, Grinding	High - Specific: Code RED	
G404	MIC-UF-A	720 Cumberland Street	Microbiology Under Floor	B	All	Inspection & Repairs	MED - Generic	
G404	MIC-UF-B	720 Cumberland Street	Microbiology Under floor	B		Hot Work, Welding, Grinding	High - Specific: Code RED	
G412	CHM2-BH-A-2		Science 2 Boiler house Side Tunnels off Biochemistry M	B		Inspection, Repairs & Hot Work	High - Generic: Code RED	
G412	CHM2-BH-B		Science 2 Boiler house Side Tunnel off Biochemist	B		Hot Work, Welding, Grinding	High - Specific: Code RED	

Confined Spaces University of Otago

G412	CHM2-BH-B-2		Science 2 Boiler house Main Tunnel to BioScience	B		Hot Work, Welding, Grinding	Low - Specific: Code Blue	
G413	CHEM2-B-B	70 Union Place West	Science 2 Basement	B		Hot Work, Welding, Grinding	High - Specific: Code RED	
G413	CHEM2-UF-B	70 Union Place West	Science 2 Basement Under floor	B		Hot Work, Welding, Grinding	High - Specific: Code RED	
G413	CHM2-A		Science 2 Basement	B	ALL	Inspection & Repairs	Low - Generic: Code Blue	
G413	CHM2-BH-A		Science 2 Boiler house Main Tunnel to Biochemistry	B		Inspection, Repairs & Hot Work	Low - Generic: Code Blue	
G413	CHM2-UF-A		Science 2 Basement Under Floor	B	ALL	Inspection & Repairs	High - Generic: Code RED	
J967		185 Hatchery Rd	PBO Marine Studies Centre tank			Cleaning.	Med - Generic: Code Blue	
H501			Under Staff Club					
F325		55 Union Street West	Physical Education	B				
D410		Frederick Street	Hayward Hall Tunnel between Hayward & Cumberland					
E201	DEN-FB-A		Dental School Boilers Steam & Heating	G		Inspection & Repairs	High – Specific: Code RED	
E201	DEN-FB-B		Dental School Boiler Room Heating & Steam Boilers	G	Boiler	Hot Work, Welding, Grinding	High - Specific: Code RED	